

CHASE "B" Points on TFX panel.

Device Test Report

Location: USCGA

Chase B

POINT LIST FOR TFX-500

Date:

Device	Address	Zone	Barcode	Location	Pass	Fail	Notes
MS	A1	1		South stair sub-bsmt			
MS	A5	1		Mech Rm Sub-bsmt			
RELAY	A7	1		HV-1 shutdown sub-bsmt			
DS	A8	1		Unit HV-1 sub-bsmt			
MS	A17	2		Trash Room sub-bsmt			
MS	A20	2		Receiving sub-bsmt			
MS	A21	2		Staging Area sub-bsmt			
HD	A22	2		Mech Rm Sub-bsmt			
MS	A25	2		Lounge sub-bsmt			
TS	A50	14		Main Sprinkler Valve			
TS	A51	14		Main Sprinkler Valve			
WF	A52	13		Main Sprinkler Waterflow			
TS	A53	14		Sprinkler Valve bsmt			
WF	A54	6		Sprinkler Waterflow			
WF	A55	12		Standpipe Waterflow			
TS	A56	14		Standpipe Valve			
WF	A57	11		Tunnel Sprinkler			
TS	A58	14		Tunnel Sprinkler			
TS	A59	14		Tunnel Low Air			
TS	A60	14		1st Floor Valve in Bsmt			
TS	A61	14		Annex Sprinkler Low Air			
WF	A62	8		Annex Sprinkler Waterflow			
TS	A63	14		Lounge Sprinkler			
WF	A64	6		Lounge Waterflow Bsmt			
WF	A65	5		Sprinkler Waterflow			
TS	A66	14		Sprinkler Valve bsmt			

CHASE "B" Points on TFX panel.

Device Test Report

Location: USCGA

Date:

Chase B

Device	Address	Zone	Barcode	Location	Pass	Fail	Notes
MS	B1	3		South Stair 1st Floor			
MS	B4	3		Wardroom South 1st Floor			
MS	B5	3		Wardroom North 1st Floor			
MS	B8	3		North Stair 1st Floor			
MS	B9	3		Courtyard 1st Floor			
DS	B10	3		Galley MUA-2 1st Floor			
Relay	B11	4		Enlisted Annex MUA-2 Shutdown			
DS	B12	4		Enlisted Annex HVAC-1			
Relay	B13	4		Enlisted Annex HVAC-1 Shutdown			
MS	B14	3		Galley Hall 1st Floor			
CMA	B15	4		Enlisted Annex Kitchen Hood			
MS	B16	4		Enlisted Annex North Annex			
MS	B17	4		Enlisted Annex Trash Room			
Relay	B18	3		MUA-1 Shutdown			
DS	B19	3		Galley MUA-1			
CMA	B20	3		Kitchen Hood H-2			
CMA	B21	3		Kitchen Hood H-1			
MS	B23	3		Kitchen			
TS	B50	14		Stair Valve 1st Floor			
WF	B51	7		Sprinkler Waterflow 1st Floor			
CMA	B99	1		MD Panel Alarm			
SDA	B100	15		Horn Circuit			
SDA	B101	15		Horn Circuit			
SDA	B102	15		Horn Circuit			
SDA	B103	15		Visual Circuit			
SDA	B104	15		Visual Circuit			
SDA	B105	15		Visual Circuit			
SDA	B106	15		Visual Circuit			