

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE	OF PAGES
2. AMENDMENT/MODIFICATION NO. 0004			3. EFFECTIVE DATE 31 January 2012	4 REQUISITION/PURCHASE REQ NO. N/A	PROJECT NO. (If applicable) N/A
6. ISSUED BY Contracting Division USCG, Facilities Design & Construction Center 5505 Robin Hood Road, Suite K Norfolk, VA 23513-2431			7. ADMINISTERED BY (If other than item 6.) Code N/A		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION NO. HSCG47-09-R-3EFK03/X0012	
			<input checked="" type="checkbox"/>	9B. DATED (SEE ITEM 11) 16 December 2011	
			<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning <u>1</u> copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (if required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).				
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
<input type="checkbox"/>	D. OTHER: (specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not <input type="checkbox"/> is required to sign this document and return ___ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)					
DESIGN AND CONSTRUCT NEW ESD/CIVPERS, BUILDING #62, U. S. COAST GUARD BASE SUPPORT UNIT, ELIZABETH CITY, NC					
1. The Price Proposal due date is changed from Tuesday, February 14, 2012 to Tuesday, March 6, 2012 .					
2. Attached is the attendance log for the organized site visit held on January 19, 2012					
(See Continuation Page)					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR (Same as Item 8)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY		16C. DATE SIGNED
_____ (Signature of person authorized to sign)			_____ (Signature of Contracting Officer)		

AMEND SOLICITATION NO. HSCG47-09-R-3EFK03/X0012 AS FOLLOWS:

SPECIFICATION: 32-3648867

SECTION 00102

1.2 RFP Drawings

Sheet C103 (4 of 11):

ADD the following Specific Note:

“17. Provide for paved maintenance truck access from existing service road or new parking to the new Telecommunications Equipment Shelter (TES). Protect new TES with concrete filled bollards”.

The following questions were received in response to the solicitation:

1. Reference 01158 - 1.12.1.5, regarding Telecomm Equipment Room HVAC systems. This paragraph includes the statement - "The air conditioning system shall be located above the ceiling and shall have a ducted supply and return.....". Finish schedule on conceptual drawings indicates no "ceiling" below the GWB lid at 12' min. Is the intent that all components of the HVAC system serving this space be routed in the truss space above the GWB lid (vs. other areas where the RFP dictates ductwork is to be routed above the suspended ceiling and below this GWB lid)?

Response: Yes, it is the intent that all components of the HVAC systems serving the ESD Build/Stor Room (Space 10) and Telecomm Equip Room (Space 11) shall be routed in the truss space above the GWB lid.

2. RFP requires the existing Thrun Hall generator to be salvaged. Please confirm the assumption that a new generator and new transformers are to be provided, and that the existing may not be re-used for the new building.

Response: A new generator and transformer are required for the new ESD/CIVPERS Building as specified in RFP specification 01158, paragraphs 1.13.2.7.1 and 1.13.1.1.2.2, respectively. The existing generator is to be relocated as directed in accordance with RFP specification 01158, paragraph 1.9.3.1 and may not be re-used for the new building.

2. Is paved vehicle access to the new telecom hut required, or will a sidewalk suffice?

Response: See amended Sheet C103 (4 of 11) above.

NOTE

Failure to acknowledge amendments may be cause for rejection of your offer.