

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE	OF PAGES
2. AMENDMENT/MODIFICATION NO. 0005			3. EFFECTIVE DATE 03/29/10	4 REQUISITION/PURCHASE REQ NO. N/A	PROJECT NO. (If applicable) 07-457957
6. ISSUED BY Contracting Division USCG, Facilities Design & Construction Center 5505 Robin Hood Road, Suite K Norfolk, VA 23513-2431			7. ADMINISTERED BY (If other than item 6.) Code N/A		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION NO. Project No. 07-457957	
			<input type="checkbox"/>	9B. DATED (SEE ITEM 11) 03/01/10	
			<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning <u>1</u> copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (if required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
<input type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).				
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
<input type="checkbox"/>	D. OTHER: (specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not <input type="checkbox"/> is required to sign this document and return ___ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)					
<b>DESIGN AND CONSTRUCT NEW AND MODIFIED EXISTING INFRASTRUCTURE REQUIRED FOR HOMEPORTING NEW FAST RESPONSE CUTTERS (FRC) AT US COAST GUARD BASE SUPPORT UNIT (BSU) MIAMI, MIAMI BEACH, FLORIDA.</b>					
<u><b>The proposal due date remains Monday, April 5, 2010 at 2:00 PM</b></u>					
<b>(SEE CONTINUATION PAGE)</b>					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR (Same as Item 8)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____		16C. DATE SIGNED
_____ (Signature of person authorized to sign)			_____ (Signature of Contracting Officer)		

**Amendment items:**

1. Specification Section 01158, paragraph 1.4.4.1.2.1: Remove existing paragraph and replace with the following:

"1.4.4.1.2.1 Provide a commercial type water meter for each new water shore tie service for Government monitoring of their water usage. Water meters shall be positive displacement type, straight reading permanently sealed magnetic drive with low flow indicator, threaded or flanged connection, manufactured and tested in accordance with ANSI/AWWA C700 standard, appropriately sized for intended service."

2. Specification Section 01158, paragraph 1.13.3.1.1: Remove existing paragraph and replace with the following:

Add to the third sentence that begins with "Conduit in ductbanks shall be a minimum size 4" PVC..."

"Conduit servicing existing loads such as lighting circuits, may be less than 4", but not less than 1 inch; conduit may be rigid galvanized steel or PVC schedule 80, with 24 inch minimum cover except where concrete encased, the conduit may be PVC schedule 40."

3. Amendment 0003 issued 3/16/10 item number 3: drawing A07457959G002, Rev should read A07457959G002 Revision A.

**NOTE**

**Failure to acknowledge amendments may be cause for rejection of your offer.**