

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES 1 OF 2
2. AMENDMENT/MODIFICATION NO. 0004	3. EFFECTIVE DATE 19 MAY 2011	4. REQUISITION /PURCHASE REQ. NO.	5. PROJECT NO. (if applicable)	
6. ISSUED BY NAVAL FACILITIES ENGINEERING COMMAND WASHINGTON 1314 HARWOOD STREET, SE WASHINGTON NAVY YARD, DC 20374-5018	CODE N40080	7. ADMINISTERED BY (If other than Item 6) SEE BLOCK 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)		(✓) X	9A. AMENDMENT OF SOLICITATION NO. N40080-11-R-9941	
			9B. DATED (see item 11) 09 FEB 2011	
			10A. MODIFICATION OF CONTRACT NO.	
			10B. DATED (see item 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input type="checkbox"/>	The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers		<input type="checkbox"/>	is extended, <input checked="" type="checkbox"/> is not extended.
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning ___ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or Letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA				
13. THIS ITEM APPLIES ONLY TO MODIFICATION OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
<input checked="" type="checkbox"/>	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGE SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.			
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, Appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).			
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: BY MUTUAL AGREEMENT OF BOTH PARTIES			
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)			
E. IMPORTANT: Contractor <input checked="" type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return Copy to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section heading, including solicitation/contract subject matter where feasible). SOLICITATION: N40080-11-R-9941-P615 SNCO Academic Facility Addition, Quantico, VA				
As an amendment to the subject solicitation, the following is hereby incorporated:				
1. Clarification regarding Amendment 0001-RFP Part 3-Chapter 6-G10, G103007 "slope stabilization".				
Continued on Page 2				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY (Signature of Contracting Officer)	16C. DATE SIGNED	

PLEASE SEE THE FOLLOWING CLARIFICATION REGARDING AMENDMENT 0001-RFP PART 3-CHAPTER 6-G10, G103007 "Slope Stabilization":

Contractor shall base their proposal on the worst case scenario from the methods specified in the RFP (drilled piers, secant piles, jet grouting and soil nailing). It is noted that the Government also directs the Offeror's attention to RFP Part 6 "Report of Preliminary Geotechnical Exploration" dated 26 October 2010 - Borings # GB-1, GB-3 & GB-4; these borings are located nearest to the area where the slope stabilization is being required per the RFP.

END OF AMENDMENT 0004