

**REQUEST FOR PROPOSAL (RFP)**  
**Langley AFB Multiple Award Construction Contract (MACC)**  
**Amendment 01**

**Issued By:** 633d Contracting Squadron/LGCB  
74 Nealy Avenue  
Langley AFB, VA 23665

28 June 2011

**Point of Contact:** Cody Hancock, (757) 764-2771

**PROJECT NUMBER:** MUHJ 08-7027 A/B

**PROJECT TITLE:** Install Electric Signage, Airfield

**Subject RFP is amended as follows: Incorporate questions below from initial site visit and change the construction period of performance from 30 days from NTP to 90 days from NTP.**

**Submission of Cost Proposals has changed. Proposals are due to the Contracting Office on 05 July 2011 at 2:00 p.m.**

Questions regarding Install Electric Signage, Airfield

1. The performance period on the RFP states 30 days, Sheet C5.1 indicates total duration of 90 days. Please clarify what the performance period will be.

- Performance period should be 90 days.

2. Sheet C5.1 references Phase I and Phase II. Please identify what the phases consist of.

- Ignore the reference to phase 1 and 2 in the drawings. Construction will commence in accordance with paragraph 1.2 of the SOW.

3. Who is to provide the radios for communications with the tower during work hours?

- The Contractor will be responsible for providing the radios and having 633 CS program them to communicate with our tower. We use either the Motorola XTS 5000s or XTS 2500 radios. In order to get the radios programmed, please contact the CFP at 4-2666 and ask them to open a ticket to program the radios. Programming will take approximately 5 minute per radio once the ticket number is addressed by CS. In addition, the radios will be considered part of the project deliverables and will be surrendered to 633 CONS at the end of construction.

4. If one sign is taken down, does it need to be replaced immediately?

- Yes, the new sign shall be operational before the existing sign is demolished.