

**STATEMENT OF WORK FOR
MULTIPLE AWARD CONSTRUCTION CONTRACT (MACC)
PROJECT MUHJ 08-4029
REPAIR / INSTALL FIRE SUPPRESSION, CONTROL TOWER, FACILITY 381
AT
LANGLEY AFB, VIRGINIA**

- 1. DESCRIPTION OF WORK:** The scope of work for this project includes the following:
 - 1.1 Fire Alarm** – replace existing fire alarm system with a new combination fire alarm/mass notification system in accordance with UFC -4021-01 and UFC 3-600-01, AFOSH and NFPA Standards.
 - 1.2 Penetrations and Doors** – seal penetrations in fire rated walls and floors with a UL listed system and replace non-fire rated doors and frames with doors and frames having appropriate fire rating in accordance with UFC 3-600-01, AFOSH and NFPA Standards.
 - 1.3 Fire Suppression System** – install a water-mist fire suppression system throughout the entire facility in accordance with NFPA 750.
 - 1.4 Utilities Upgrade** – include any upgrade work associated with utilities to support above design.

- 2. PROGRAM MANAGEMENT:** The contractor shall sequence his work to ensure progress efficient for occupancy and use.
 - 2.1 COMMENCEMENT, PROSECUTION AND COMPLETION OF WORK:**
No design effort is required
 - 2.2 SUBCONTRACTORS:**
No Variance.
 - 2.3 QUALITY CONTROL PLAN:**
No variance.

- 3. RESPONSE REQUIREMENT**
No variance.

- 4. DESIGN DOCUMENTS, GENERAL:**
No design effort is required.
 - 4.1 DRAWINGS, BID SCHEDULE AND COST ESTIMATE:**
No variance.
 - 4.2 DRAWING:**
No variance.
 - 4.3 RENDERED PERSPECTIVE:**
No variance.
 - 4.4 SPECIFICATIONS:**
No variance.

REPAIR / INSTALL FIRE SUPPRESSION, CONTROL TOWER, FACILITY 381

4.5 CONSTRUCTION COST ESTIMATE BREAKDOWN:

No variance.

4.6 PREPARATION OF AF FORM 66, Schedule of Material Submittals:

No variance.

4.7 BID SCHEDULE:

A bid schedule is furnished.

5. DESIGN ANALYSIS:

No variance.

6. CONTRACT DOCUMENTS SPECIAL REQUIREMENTS:

No variance.

7. APPLICABLE CODES AND REGULATIONS:

No variance.

8. GOVERNMENT POINTS OF CONTACT:

633 CES Project Manager –	W. Daniel PORTER, PE	633 CES/CEPM	(757) 764-1149
633 CES Project Inspector –	Joseph A. SIROIS	633 CES/CEPM	(757) 764-9564
Facility Managers –	Aldarko ALLEN	633 OSS/OSAT	(757) 764-5327
	Kerry HALL	633 OSS/OSAT	(757) 764-5326