

REQUEST FOR PROPOSAL (RFP)
Langley AFB Multiple Award Construction Contract (MACC)
Amendment 01

Issued By: 633d Contracting Squadron/LGCB
74 Nealy Avenue
Langley AFB, VA 23665

21 September 2011

Point of Contact: Samuel W. Brown, 225-5256 or Michael Costlow, 764-2597

PROJECT NUMBER: MUHJ 09-4017

PROJECT TITLE: Repair AGE, Facility 757

The purpose of Amendment 01 is to incorporate Question and Answers into the RFP:

QUESTIONS AND ANSWERS:

In further review the solicitation documents for Repair AGE Facility, 757, we find further clarification is needed on the following:

1. Architectural – Door Schedule A601 lists Door Mark 117 with Hardware Set #3, but Hardware Schedule in Section 08 71 00 Door Hardware does not list Door 117. Should Door 117 be listed along with Door 104 for Hardware Set #3?
(YES)
2. Architectural – Room Finish Schedule, Sheet A-602, notes there is an additive bid for 117 Open Bay. Sheet A-101 New Work Keyed Note 1 also notes additive bid for new floor finish. Where are we to provide this additive bid on the Bid Schedule?
(YES)
3. Architectural – Sheet A-101 has a Item A in the Equipment Schedule that has Microwave as “CFCI” as well as a Note on Elevation A/A-401, but I can find no specification for the microwave. What is the desired microwave that we are to provide?
(The Microwave will be Government Furnished- Contractor Installed GFCI)
4. Architectural – Sheet A-401 Break Room Elevation B does not appear to have a return at the left end to join up with Elevation A as shown on Sheet A-102. Please review and advise if a cabinet return is desired at the left end of Elevation B?
(YES; a cabinet return is desired at the left end of Elevation B)
5. Architectural – Sheet A-103 Reflected Ceiling Plan Note 1 states that we are to “PROVIDE NEW POLY-FACED R-30 BATT INSULATION EXTENDING UP EXTERIOR WALLS AND UNDER EXISTING ROOF DECK/SUBSTRATE. PROVIDE SUPPLEMENTAL FURRING @ 24” O.C. TO RECEIVE NEW INSULATION.” What is the height that we are to use for bottom of roof deck?
(20 Feet)

