

Bldg #	Area/Location	Description	Collection Date	Impact/ Concentration %	Exceeds Limit?
891	Lobby floor		27-Mar-92	10% chrysotile	Y
891	Lobby floor		27-Mar-92	15% chrysotile	Y
891	Lobby floor		27-Mar-92	20% chrysotile	Y
891	Lobby floor		27-Mar-92	10% chrysotile	Y
891	Storage room floor		27-Mar-92	10% chrysotile	Y
891	Storage room floor		27-Mar-92	30% chrysotile	Y
891	Storage room floor		27-Mar-92	<1% chrysotile	N
891	Storage room floor		27-Mar-92	10% chrysotile	Y
891	Storage room floor		27-Mar-92	<1% chrysotile	N
891	Flight tech room floor		27-Mar-92	30% chrysotile	Y
891	Flight tech room floor		27-Mar-92	<1% chrysotile	N
891	Flight tech room floor		27-Mar-92	30% chrysotile	Y
891	Mgr office floor	brown, adhesive material	27-Mar-92	ND	N
891	Mgr office floor	black, tile material	27-Mar-92	10% chrysotile	Y
891	Mgr office floor	black, tar material	27-Mar-92	25% chrysotile	Y
891	Mgr office floor	gray, tile material	27-Mar-92	10% chrysotile	Y
891	Mgr office floor	black, tar material	27-Mar-92	10% chrysotile	Y
891	Mgr office floor	brown, fibrous material	27-Mar-92	ND	N