

REQUEST FOR PROPOSAL (RFP)
Langley AFB Multiple Award Construction Contract (MACC)
Amendment 03 to Repair Facility For F-22A Maintenance, Facility 369

Issued By: 1st Contracting Squadron/LGCB
74 Nealy Avenue
Langley AFB, VA 23665

24 September 09

Point of Contact: SSgt Rebecca Riddick 757-764-4902, SSgt Charles Craig 757-764-4902,
Gregory Davenport, 757-764-2771

PROJECT NUMBER: MUHJ 08-4061

PROJECT TITLE: Repair Facility For F-22A Maintenance, Facility 369

Subject RFP is amended as follows:

The following clarifies recently received questions concerning this project:

1. Reference is made to bid item 0004. What is meant by “complete” in...”and rewiring of the building complete in accordance...”?

Response: If option for the transformer is picked up, this statement is meant to instruct the Contractor(s) that the installation of the transformer and associated wiring of the facility to accommodate such electrical support must be accomplished complete in accordance with the project design documents (drawings, spec's, et cetera).

2. On sheet A102 under the material schedule, we need a clarification on the carpet? The schedule refers to a VCT manufacturer & a VCT description / color for the carpet.

Response: In the "MATERIAL SCHEDULE", please instruct the Contractor to change "CARPET" and "CPT" reference to "VINYL COMPOSITION TILE" and "VCT", respectively. The information noted in the schedule is for VCT. It would not be practical to place carpet in the Break Room, Decon Rooms, and the Clean Rooms.

3. VCT selected for the decon, break room and clean rooms is indeed based on Armstrong, Charcoal 51915 or equal. Carpet for the Office is Mannington Commercial (Balanced - Montreal) or equal.

Note: The Previous Amendment was mis-labeled as 3, and should be 2. This Amendment is #3, which brings the total to 3 Amendments.

The cost proposal due date remains unchanged, 28 September 2009 at 12:00 p.m.