

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0002		3. EFFECTIVE DATE 09/15/08	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 08-0016	
6. ISSUED BY Resident Officer in Charge of Construction 1005 Michael Road Camp Lejeune, NC 28547-2521		CODE mks	7. ADMINISTERED BY (If other than Item 6) See Item 6		CODE
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-08-R-0016
				x	9B. DATED (SEE ITEM 11) 09/03/08
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE			

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
 (a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

08-0016, Interior/Exterior Repairs, Building 342

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR  (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA  (Signature of Contracting Officer)	16C. DATE SIGNED

CONTINUATION SHEET

1. Question: Does the gov't want the lead paint removed completely down to the substrate or enough to allow for encapsulation with the new paint coating?  
  
1. Answer: Surfaces shall be prepped so that new paint can be applied. Chipped, peeling, or blistered paint shall be removed and the surface spot primed. Collect and test paint debris and if the paint debris tests positive for lead dispose of it in accordance with Specification Section 02 82 33.12.
  
2. Question: Amendment 1 told us to bring the utilities from the road to the Bldg. We need to know more information like sizing, lengths, where is the existing located.  
  
2. Answer: Provide a 4" sewer line from the 4" CO depicted on Sheet P-1 to the 8" gravity main north of BLDG 342 that runs parallel to the access road. Tap into the existing 8" gravity main, distance of run is approximately 255 ft. Provide a 1.5" water line from the main cut-off depicted on Sheet P-1 to the 8" water main south of BLDG 342 that runs parallel to H Street. Tap into the existing 8" water main, distance of run is approximately 180 ft. Saw cut and patch asphalt necessary to access water/sewer lines for tapping purposes.
  
3. Question: Sheet A-3 Detail C/A3/A3 "new privacy screen" should that read "new insect screen"? If a new privacy screen is required please provide a detail drawing and specs.  
  
3. Answer: See Specification Section 08 51 13.00 40, Paragraph 2.2.

