

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE	PAGE OF PAGES 1   3
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0003		3. EFFECTIVE DATE 09/05/07	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 02-3467	
6. ISSUED BY Resident Officer in Charge of Construction 1005 Michael Road Camp Lejeune, NC 28547-2521		CODE mks	7. ADMINISTERED BY (If other than Item 6) See Item 6		CODE
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-02-R-3467
				X	9B. DATED (SEE ITEM 11) 08/07/07
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE			

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.  
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
 (a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;  
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

**E. IMPORTANT:** Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  
 02-3467, Major Interior/Exterior Repairs, Building 3

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

**1. Question: How many fire extinguishers? Specs state to furnish and install as called for on plans.**

**1. Answer: Provide 50 fire extinguishers and built in cabinets. Locate as directed in building 3 and other buildings.**

2. Question: How many interior signs? Plan schedule states 2 @ each restroom but specs state as indicated on the drawings. Problem is there are two types of signs shown on the drawings.

2. Answer: See table on A7 for quantity of signs.

**3. Question: Is ceiling grid being demo'd?**

**3. Answer: Demolish existing suspended ceiling complete including grid. Provide new suspended ceiling complete in areas noted "Lay-in" on finish schedule on A6.**

4. Question: Two sizes of backer board. Which is correct, 1/2" or 5/8"?

4. Answer: All backer board shall be 5/8" in thickness.

**5. Question: Are we to assume drywall is installed under the ACT? Demo notes #7 & 9.**

**5. Answer: Provide 5/8" gypsum attached to existing framing entire second floor ceiling. Tape, fire caulk, and prime gypsum. This ceiling only serves as a moisture and air barrier between the attic and the building.**

6. Question: Rigid insulation. There are two sizes shown. Plans are 1 1/2" & specs call for 2". Which is correct?

6. Answer: All rigid insulation shall be 2" thick .

**7. Question: Are we furnishing and installing projection screens and projectors? Drawings show motorized, typical. If so, how many?**

**7. Answer: Quantity of projection screens is indicated on the drawings.**

8. Question: 16403 3.1.3.6 refers to MC cable; are we allowed to use it?

8. Answer: MC cable is not allowed.

9. Question: Amendment #2, Note #8 states to provide new underground pipe. The specs do not include a pre-insulated pipe spec.

9. Answer: Underground piping shall be factory designed piping system with schedule 80 steel carrier with steel conduit. Insulation shall be 3" thick cellular glass. Coat conduit with epoxy paint.