

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0001		3. EFFECTIVE DATE 03/06/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 09-0416
6. ISSUED BY CODE		lfp	7. ADMINISTERED BY (If other than Item 6) CODE	
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521		See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-09-R-0416
			x	9B. DATED (SEE ITEM 11) 02/20/09
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

09-0416, Remove Asbestos from Bldgs 13, 33, 1111, 1203, 1505, & M307

(SEE CONTINUATION SHEET)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

QUESTION (1): Are there insulation specs/details available of each of these buildings?

ANSWER (1): At buildings 1111, 1203, and 1504 the piping runs are readily accessible. Any additional detail, in regards to site interference, should be acquired via a contractor site visit. The government is allowing access to the buildings for prospective bidders. All of the buildings are manned during normal working hours with the exception of building 1203, for which a point of contact has been provided in the scope of work. Additionally, Public Works Operations will assist with site visits, and can be contacted at building 1005, phone (910) 451-3579.

QUESTION (2): Bldg 1111 – Does the spec suggest 130 LF of each size of piping or 130 LF collectively? Is anything exposed? Will the piping need additional jacketing? What type and thickness of insulation is to be reinstalled?

ANSWER (2): The 130 LF is collectively. No additional jacketing is needed. The insulation will be cellular glass, 2 inches thick. There are 6ea 90 degree ells and 6ea 45 degree ells.

QUESTION (3): Bldg 1203 – What size pipe is to be reinsulated? Is anything exposed? What type of access is there to the piping?

ANSWER (3): The piping is ½ inch water piping to be reinsulated with 1.5 inch thick cellular glass insulation, covered with an ASTM-C-1136 vapor barrier. There are 9ea 90 degree ells.

QUESTION (4): Bldg 1505 – Does spec suggest 60 LF of each size of insulation or 60 LF collectively? Is anything exposed?

ANSWER (4): 60 LF collectively. There are 10ea 90 degree ells.

QUESTION (5): Bldg M307 – What thickness/type of insulation is required? What type of jacketing? What size piping?

ANSWER (5): The tank insulation will be 2 inch thick ASTM-C-552 cellular glass covered with an ASTM-C-1136 vapor barrier. The piping is 1” IPS to be insulated with cellular glass, 2 inches thick, with an ASTM-C-1136 vapor barrier. There are 3ea 90 degree ells. No jacketing required.

QUESTION (6): Bldg 13 – What size piping? Does pipe need jacketing? (Aluminum?)

ANSWER (6): No jacketing required on the new insulation. Pipe size is 1” IPS, located in a steam pit. There are 7ea 90 degree ells.