

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0002		3. EFFECTIVE DATE 05/29/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 08-0188	
6. ISSUED BY CODE		CODE rmb	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6		
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521					
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-09-R-5308	
			X	9B. DATED (SEE ITEM 11) 05/15/09	
				10A. MODIFICATION OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 11)	
CODE	FACILITY CODE				

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

N40085-09-R-5308, MULTIPLE AWARD CONSTRUCTION CONTRACT (MACC), GENERAL CONSTRUCTION PROJECTS, NORTH CAROLINA AREA

~ SEE CONTINUATION PAGE ~

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. QUESTION: On solicitation # N4008509R5308 would a vinyl ATFP window be an acceptable alternative to an aluminum ATFP window.
ANSWER: The requirement is for an aluminum window.
2. QUESTION: The work includes removing existing windows from the building and provide and install new aluminum ATFP windows and wood window stools at each window location. Is there more detailed information available regarding the specification of the type, size and quantity of windows?
ANSWER: The solicitation contains for "REFERENCE ONLY" drawings; additionally the Building RR-4 is available for site visit/inspection for field verifications. Specification Sections 08.51.13 and 08.56.53 state window requirements.
3. QUESTION: There are two spec sections covering the windows, 085113 aluminum windows and 085653 blast resistant tempered glass windows. Do we use both sections for all windows; if so which section has precedence? Section 085113 aluminum windows calls for blast windows in paragraph 1.8 but the two sections are different.
ANSWER: The intent of the specification section 085113 is to specify the window frame and section 085653 is to specify the glazing requirements and should be bid in this way.
4. QUESTION: Are the existing windows attached to steel studs?
ANSWER: For bidding purposes assume that the existing windows are attached to steel studs that will have to be replaced. The specifications require a window with a sub frame.
5. QUESTION: There are approximately 40 locations where the windows have been in filled with brick. The concrete sills are still in place. Should these be cleaned and painted to match the window sills at the new windows?
ANSWER: New windows should only be installed where windows are presently located and all concrete sills are to be cleaned and painted.
6. QUESTION: The Solicitation, Offer and Award Form 1442, Number 13 asks for 5 copies of the price quote. On Page 48 of 71 of the RFP under the Proposal Requirements calls for 1 copy plus one CD for the price quote. Which one is correct?
ANSWER: The requirements for Volume (1), (PRICE), on Page 48 of Section 00800, Special Contract Requirements will govern.
7. QUESTION: Most contractors do not complete the price portion of the proposal until just before the due time. Therefore, providing an electronic copy of the pricing on a CD at the proposal due time is not practical.
ANSWER: DELETE the requirement for a CD for Volume (1), (PRICE).
8. QUESTION: On page 18 paragraph (ii) it says if a Small Business submitted a complete application to the Small Business Administration to be certified as a small disadvantaged business concern in accordance with 13 CFR 124, Subpart B, and a decision on that application is pending, and that no material change in disadvantaged ownership and control has occurred since it's application was submitted that Small Business are eligible to participate in a bid for the above referenced project as a small disadvantage business. Is this right? Does letter about pending application need to be submitted?
ANSWER: Section 00600, Representations & Certifications, are self-certifying. A letter is not required with submission of the offeror's proposal.
9. QUESTION: I can not find in the project specifications what blast rating is required for the new windows. What is the psi or blast resistance requirement?
ANSWER: Please refer to Specification Section 08.51.13, Page 7, Paragraphs 1.8 through 1.8.3.